SECTION 00 02 00 - NOTICE TO BIDDERS

NOTICE TO BIDDERS

Notice is hereby given that sealed bids will be received:

By:	Duneland School Corporation 601 W. Morgan Avenue Chesterton, IN 46304
For:	Liberty and Westchester Intermediate Schools - Athletic Site Projects Liberty Intermediate School 50 West 900 North Chesterton, IN 46304
	Westchester Intermediate School 1050 S. 5 th Street
	Chesterton, IN 46304
At:	Duneland School Corporation - Administration Office 601 W. Morgan Avenue Chesterton, IN 46304
Until:	10:00AM (CST) on August 2, 2022
Bid Opening:	Bids will be received until 10:00AM (CST) on August 2, 2022, at the Duneland School Corporation – Administration Building located at 601 W Morgan Ave, Chesterton, IN 46304.

All work for the complete construction of the Project will be under one or more prime contracts with the Owner based on bids received and on combinations awarded. The Construction Manager will manage the construction of the Project.

Construction shall be in full accordance with the Bidding Documents which are on file with the Owner and may be examined by prospective bidders at the following locations:

Office of the Construction Manager The Skillman Corporation 8006 Aetna Street Merrillville, IN 46410 The Skillman Plan Room www.skillmanplanroom.com

Duneland School Corporation - Administration Office 601 W. Morgan Avenue Chesterton, IN 46304 <u>Prime and Non-Prime Contract Bidders</u> must place an order on <u>www.skillmanplanroom.com</u> to be able to download documents electronically or request printed documents. There is no cost for downloading the bidding documents. Bidders desiring printed documents shall pay for the cost of printing, shipping, and handling. Reprographic Services are provided by:

Reprographic Arts, 2824 E. Michigan Blvd., Michigan City, IN 46360, Phone (219) 872-9111

A Pre-Bid Conference will be held on July 12, 2022 at 11:00 AM (CST) at Westchester Intermediate School followed by Liberty Intermediate School. Attendance by bidders is optional, but recommended, in order to clarify or answer questions concerning the Drawings and Project Manual for the Project. Bid security in the amount of ten percent (10%) of the Bid must accompany each Bid in accordance with the Instructions to Bidders.

The successful Bidders will be required to furnish Performance and Payment Bonds for one hundred percent (100%) of their Contract amount prior to execution of Contracts.

Contractors submitting bids for the performance of any Work as specified in this building Project should make such Bids to **Duneland School Corporation**. Contractors are advised that the Contract as finally entered into with any successful Bidder may be entered into with either the School Corporation or the Building Corporation or certain portions of the Contract may be entered into by both the School Corporation and the Building Corporation.

The Owner reserves the right to accept or reject any Bid (or combination of Bids) and to waive any irregularities in bidding. All Bids may be held for a period not to exceed **60** days before awarding contracts.

Duneland School Corporation

By: Dr. Chip Pettit, Superintendent

END OF SECTION 00 02 00

SECTION 01 12 00 - MULTIPLE CONTRACT SUMMARY

PART 1 - GENERAL

1.01 RELATED DOCUMENTS

A. Drawings and General Provisions of the Prime Contract, including amended General Conditions and other Division 1 Specification Sections, apply to Work of this Section.

1.02 SUMMARY

- A. The intent of this Section is to indicate the Work required by the Contractors and to provide information regarding the duties, responsibilities, and cooperation required by the Contractors, with similar requirements for the subcontractors and suppliers.
- B. Owners right to maintain current operations
- C. Occupancy requirements
- D. Work by Owner
- E. Permits, fees, and notices
- F. Labor and materials
- G. Verifications of existing dimensions
- H. Project security
- I. Coordination of work
- J. Time of commencement and completion
- K. Schedule of contract responsibilities

1.03 WORK UNDER SEPARATE CONTRACTS

- A. Prime Contracts are defined to include the following contracts described in the Schedule of Contract Responsibilities included hereinafter; and each is recognized to be a major part of the project, with Work to be performed concurrently and in close coordination with Work of other Prime Contracts.
- B. The "Contract Documents," as defined in the General Conditions, include "the Drawings." Although Drawings are grouped and identified by classification of the Work, Contractors shall be responsible for their Work as specified herein and as

indicated on the Drawings. Although the majority of the Drawings are "to scale," Contractors are directed to use indicated dimensions for determining material quantities and for other reasons. No additional monies will be allowed due to Contractors using "scaling instruments" to determine material quantities or for other reasons.

- C. Separate prime contracts will be awarded as per the "Schedule of Contract Responsibilities" (see Part 3 Execution). Contractors shall include Work required by the Specifications and Drawings for each contract area defined in the Schedule.
- D. Work for the complete construction of the Project will be under multiple prime contracts with the Owner. The Construction Manager will manage the construction of the Project.
- E. Each Contractor shall be responsible for demolition and disposal of existing items relative to his Contract.

1.04 ADMINISTRATIVE RESPONSIBILITIES OF PRIME CONTRACTORS AND CM

- A. The Construction Manager shall be responsible for the maintenance of the Construction Schedule and management of every phase of the Work.
 - 1. Each Contractor shall read the Specifications and Drawings for other separate Contracts for fixed equipment and the like to be incorporated or attached or built into the Work; and familiarize himself with the requirements and responsibilities of other Contracts to enable the required coordination and supervision.
 - 2. Each Contractor shall also familiarize himself with other items to be incorporated into the Work including equipment and Work by the Owner.
 - 3. Each Contractor shall cooperate with the Construction Manager in notifying him when the Work is at a stage to require the services of other Contractors and shall notify the Construction Manager in the event that such other Contractors do not carry out their responsibilities in connection with such notification.
- B. Contractors shall cooperate with and assist the Construction Manager in the preparation of construction progress and procedures, schedule of product deliveries, and their effect on the overall project progress and completion. Other Contractors shall cooperate in getting their Work and the Work of their subcontractors completed according to the schedule as prepared and maintained by the Construction Manager. Each Contractor shall immediately notify the Construction Manager of a delay in delivery of products or the scheduled date of completion that may affect the total progress of construction.
- C. The Owner will furnish the topographical survey, either as a part of these Drawings or separately, giving the general topographical lines existing at the site and the property lines.

D. Contractors required to make connections to existing utilities, especially sewerage where gravity flow occurs, shall verify grades and locations at points of such connections and shall notify the Construction Manager of circumstances which would adversely affect the proper flow or connection to such facilities.

1.05 PRIME CONTRACTORS USE OF PREMISES

- A. Use of the Site: Limit use of the premises to work in areas indicated. Confine operations to areas within contract limits indicated. Do not disturb portions of the site beyond the areas in which the Work is indicated.
 - 1. Owner Occupancy: Allow for Owner occupancy and use by the public.
 - 2. Driveways and Entrances: Keep driveways and entrances serving the premises clear and available to the Owner, the Owner's employees, and emergency vehicles at all times. Do not use these areas for parking or storage of materials. Schedule deliveries to minimize space and time requirements for storage of materials and equipment on site.
- B. Use of the Existing Building: Maintain the existing building in a weathertight condition throughout the construction period. Repair damage caused by construction operations. Take all precautions necessary to protect the building and its occupants during the construction period.

1.06 OWNERS RIGHT TO MAINTAIN OPERATIONS

- A. During the course of this Project, normal and customary functions and operations must be maintained. The Contract Documents are intended to define a strict separation between the school activities of students and staff from the activities of the construction project.
- B. The Construction Manager, Architect, and Owner will not tolerate any visible or audible actions initiated or responded to by any employees of Contractors on this Project toward any students, teachers, or staff members at the school system. Violators shall be promptly removed from the site.
- C. The Owner intends to instruct students, teachers, and staff to refrain from communications with Contractor's personnel working on this Project. All communication with Owner and staff shall be through the Construction Manager.
- D. Contractors must expend their best effort toward protection of the health, safety, and welfare of occupants on the Owner's property during the course of Work on this Project.

1.07 OCCUPANCY REQUIREMENTS

A. Full Owner Occupancy: The Owner will occupy the site and existing building during the entire construction period. Cooperate with the Owner during

construction operations to minimize conflicts and facilitate Owner usage. Perform the Work so as not to interfere with the Owner's operations.

- B. Partial Owner Occupancy: The Owner reserves the right to occupy and to place and install equipment in completed areas of the building prior to Substantial Completion, provided such occupancy does not interfere with completion of the Work. Such placing of equipment and partial occupancy shall not constitute acceptance of the total Work.
 - 1. The Construction Manager will prepare a Certificate of Substantial Completion for each specific portion of the Work to be occupied prior to Owner occupancy.
 - 2. Party which obtained general building permit shall obtain a Certificate of Occupancy from local building officials prior to Owner occupancy.
 - 3. Prior to partial Owner occupancy, mechanical and electrical systems shall be fully operational. Required inspections and tests shall have been successfully completed. Upon occupancy, the Owner will operate and maintain mechanical and electrical systems serving occupied portions of the building.
 - 4. Upon occupancy, the Owner will assume responsibility for maintenance and custodial service for occupied portions of the building.

1.08 WORK BY OWNER

- A. The Owner intends to complete the following items of Work outside the provisions of these Contract Documents. Contractors shall not restrict or interfere with the Owner's right to the Project to accomplish this Work.
 - 1. Equipment and furniture except as scheduled and specified under Divisions 11 and 12 and shown on the Drawings.
 - 2. Items which may be deleted from Contracts for Work as required by the Contract Documents.
 - 3. Existing school maintenance work.
 - 4. The purchase and supplying of certain materials as noted in the Project Manual.
 - 5. The Owner, under separate contract, shall provide removal of identified asbestos containing materials from the existing structure. The asbestos report is available through the Construction Manager upon request.

1.09 PERMITS, FEES, AND NOTICES

- A. The **Construction Manager** will secure the general building permit for the Owner. Each Contractor shall secure and pay for other permits, governmental fees, and licenses necessary for the proper execution and completion of his Work, which are applicable at the time the bids are also received. Fees to relocate utilities on Owner's property shall be included in the bid of the Contractor doing the relocation.
 - 1. State filing fees for plan approval are the responsibility of the Owner and will be paid by the Owner.

- B. Utility Tie-Ins: Shall be arranged with local utility company and other involved parties for minimum interruption of service.
- C. Shutdowns of existing systems shall be limited to minimum time required and scheduled with other involved parties. Provide 2 days written notice of shutdown to Construction Manager and Owner.
- D. Inspections of installed work shall be performed by the governing authority as arranged for by the Contractor. Work shall not be covered until approved.
- E. Each Contractor shall give notices and comply with laws, ordinances, rules, regulations, and orders of public authorities bearing on the performance of his Work. If a Contractor observes that the Contract Documents are at variance therewith, he shall promptly notify the Construction Manager in writing, and necessary changes shall be adjusted by appropriate notification. If a Contractor performs Work knowing it to be contrary to such laws, ordinances, rules, and regulations, and without such notice to the Construction Manager, he shall assume full responsibility therefore and shall bear the costs attributable thereto.

1.10 LABOR AND MATERIALS

- A. Unless otherwise specifically noted, the Contractor shall provide and pay for labor, materials, equipment, tools, construction equipment and machinery, water, heat, utilities, transportation, and other facilities and services necessary for the proper execution and completion of his Work, whether temporary or permanent and whether or not incorporated or to be incorporated in the Work.
- B. Each Contractor shall enforce strict discipline and good order among his employees or other persons carrying out Work of his Contract and shall not permit employment of unfit person or persons or anyone not skilled in the task assigned to them.
- C. Contractors and Subcontractors shall be subject to such rules and regulations for the conduct of the Work as the Owner may establish. Employees shall be properly and completely clothed while working. Bare torsos, legs and feet will not be allowed. Possession or consumption of alcoholic beverages or drugs, tobacco or other noxious behavior on the site is strictly prohibited. Violators shall be promptly removed from the site. Smoking is not permitted on school property or within school buildings.
- D. Contractors will conduct criminal background checks (extent of and/or service to be used will be established by the Owner) on every employee assigned to work on the Project and clear them through the National Sex Offender Registry prior to their assignment to Project. Contractors will require the same of sub-contractors.

- E. ID Badges will be issued by The Skillman Corporation upon receipt of verification from the Contractor that the employee/subcontractor employee or independent contractor has a satisfactory record to work on the Project.
- F. <u>E-Verify Compliance</u>: Pursuant to I.C. 22-5-1.7, Contractor shall enroll in and verify the work eligibility status of all newly hired employees of Contractor through the E-Verify Program (Program). Contractor is not required to verify the work eligibility status of all newly hired employees through the Program if the Program no longer exists. Also pursuant to I.C. 22-5-1.7, Contractor must execute an affidavit affirming that the Contractor does not knowingly employ an unauthorized alien and confirming Contractor's enrollment in the Program, unless the Program no longer exists, shall be filed with the Owner prior to the execution of this contract. This contract shall not be deemed fully executed until such affidavit is delivered to the Owner.

Contractor and its subcontractors shall not knowingly employ or contract with an unauthorized alien or retain an employee or contract with a person that contractor or its subcontractor subsequently learns is an unauthorized alien. If Contractor violates this provision the Owner shall require Contractor to remedy the violation not later than thirty (30) days after the Owner notifies Contractor. If Contractor fails to remedy the violation within the thirty (30) day period, the Owner shall terminate the contract for breach of contract. If Owner terminates the contract, Contractor shall be liable to the Owner for actual damages in addition to any other contractual remedies. There is a rebuttable presumption that Contractor did not knowingly employ an unauthorized alien if Contractor verified the work eligibility status of the employee through the Program.

Prior to performing any work, Contractor shall require each subcontractor to certify to Contractor that the subcontractor does not knowingly employ or contract with an unauthorized alien and has enrolled in the Program. Contractor shall maintain on file a certification from each subcontractor throughout the duration of this contract or project which is the subject of this contract. If Contractor determines that a subcontractor is in violation of this provision, Contractor may terminate its contract with the subcontractor for such violation. In Accordance with I.C. 5-16-13 Contractor must provide the E-Verify Case Number of every employee that works on the project. This requirement includes the contractor's subs and suppliers to the fourth (4th) tier.

- G. The Owner is requiring that all contractors' personnel and their onsite employees and subcontractors submit to expanded history and child protection index check. Contractors shall enroll in the Safe Vendor Program through Safe Hiring Solutions <u>www.safehiringsolutions.com</u>. Enrollment in Safe Vendor will ensure contractors employees are vetted in accordance with I.C. 20-26-5-10 for expanded criminal history and expanded child protection index check. Contractor is responsible for the cost of enrollment and employee background check. All contractors' personnel and employees, once cleared for work will be issued a project identification badge that must be worn at all times while on site. All contractors/subcontractors employees shall provide name, address, picture state driver's license or picture identification card and/or Safe Vendor Card to The Skillman Corporation Site Manager upon request.
- H. Pursuant to Indiana Code 5-16-13 Requirements for Contractors on Public Works Projects enacted by the Indiana Legislator requires, in addition to requirements already in effect, contractors to comply with the following:
 - 1. Tier 1 –General/Prime Contractors to self-perform 15% of their total Contract.
 - 2. Qualification thru the Department of Administration or INDOT requirement in accordance with IC 4-13.6-4.
 - a. Bids shall not be considered unless (1) the Prime Bidder and (2) all lower tiered subcontractors whose subcontract value is estimated to be \$300,000 or more are qualified at the time of the bid in accordance with IC 4 13.6 4.
 - 3. Include Written Drug Testing Plan that covers all employees of the bidder who will perform work on the public work project and meets or exceeds the requirements set in IC 4-13-18-5 or IC 4-13-18-6 with Bid.
 - 4. Minimum Insurance Requirements \$1M/occurrence \$2M/aggregate. However, check your bidding requirements as the Owners may have higher limit requirements.
 - 5. Mandatory enrollment in E-Verify by all contractors down to the 4th Tier Sub Contracts and must provide the case verification number of all employees working on the project.
 - 6. Prohibits contractors down to the 4th Tier Sub Contract from paying employees in cash.
 - 7. Requirement to retain payroll records for 3 years
 - 8. All contractors down to the 4th Tier Sub Contract must comply with Fair Labor Act, Indiana's Workers Compensation and Unemployment Compensation Insurance.
 - 9. Mandatory Training Requirements based upon number of employees.
 - 10. Failure to comply may result in debarment from public works projects for up to 4 years.

I. All contractors down to the 4th Tier Sub Contract must maintain general liability insurance in at least the following amounts: Each Occurrence Limit of \$1,000,000 and General Aggregate Limit of \$2,000,000. Other requirements and limits may apply see specification section 00 08 20 Schedule of Insurance Requirements.

1.11 CUTTING AND PATCHING

A. Refer to Section 01 73 10 – Cutting and Patching, for provisions on this subject.

1.12 VERIFICATIONS OF EXISTING DIMENSIONS

A. When verification of existing dimensions is required, the Contractor requiring said verification for the construction or fabrication of his material shall be the Contractor responsible for the procurement of the field information.

1.13 PROJECT SECURITY

- A. Each Prime Contractor shall take all reasonable precautions to prevent injury, damage or loss to people and property in, on and adjacent to the project. This shall include not only their own work or property but that of other contractors and the Owner.
- B. If deemed necessary by The Construction Manager a project wide security program may be developed for the purpose of preventing damage or loss at the project site or property adjacent thereto. Once accepted by the Owner, contractors shall comply.

1.14 SCHEDULE OF CONTRACT RESPONSIBILITIES - SCOPE

- A. Contractors shall submit their proposals based on the work included under each contract area as listed herein. Include Work necessary for a complete project, as shown on the Drawings and called for in the Specifications.
- B. Questions concerning the phasing, or "Schedule of Contract Responsibilities" should be directed to the Construction Manager, who will be the interpreter and be responsible for this Schedule of Contract Responsibilities and Contract Breakdown, prior to submitting proposals and during construction.
- C. The requirements of Division 1 are a part of the Work of each and every contract area. The Contractor for any one contract area shall be familiar with the Work and requirements of all other contract areas.
- D. Certain Specification Sections describe Work to be performed under several contract areas. (Example: 06 10 00 Rough Carpentry.) Provide Work of this nature as required for each contract area whether or not enumerated in the Schedule of Contract Responsibilities.

- E. The following contract areas are broken down by Specifications Section conforming basically to the CSI format.
- F. The Drawings and Specifications as furnished for each of the Contracts is for the convenience of the Contractor in preparing a proposal for this Project. However, each Contractor is responsible to review the complete set of Drawings and Specifications to assure that Work required to be installed to complete his phase of the Work is included in his proposal. This "Schedule of Contract Responsibilities" is a definition of the work as it is to be bid in separate contracts. Where a specific item of Work is not defined, but is normally inherent to a trade, or is included in the scope of the applicable technical revision, it will be the responsibility of that Contractor to include the Work in his proposal.
- G. This "Schedule of Contract Responsibilities" is to aid each Contractor in defining the Scope of Work to be included in his proposal. However, omissions from this "Schedule of Responsibilities" do not relieve the Contractor from including in his proposal that Work which will be required to complete his Contract. Each Contractor should read the "Schedule of Contract Responsibilities" completely to familiarize himself with the Work of other Contractors that may have Work in adjacent areas and to coordinate the interfacing problems that may occur as the work is assembled and constructed.
- H. Where specific Work is to be completed under a particular phase of the Project and the Work is wholly or partially completed by other trades because of the type of work involved or jurisdictional trade agreements, the Contractor will be responsible to subcontract the Work as necessary to complete the Work included in his Contract. No delay in the Work will be allowed due to the failure of the Contractor to subcontract related work required by jurisdictional trade agreements.

1.15 COORDINATION OF WORK

A. Each Contractor is responsible to coordinate his Work with the Work of other trades and other Contractors and requirements of the school system. The Contractor must make space allowances for Work of other Contractors; provide necessary openings where indicated or implied by the Drawings and Specifications. Each Contractor is responsible to protect his own Work.

1.16 TIME OF COMMENCEMENT AND COMPLETION

- A. The Contractor shall commence work within ten (10) days after being notified in writing to proceed and shall complete the Work within the time limitations established in the Form of Agreement.
 - 1. It is anticipated that construction will start within (34) calendar days after receipt of bids.
 - 2. Construction shall be complete within (324) consecutive calendar days, or earlier, after Notice to Proceed.

PART 3 - EXECUTION

3.01 SCHEDULE OF CONTRACT RESPONSIBILITIES

3.02 GENERAL REQUIREMENTS

A. PROVIDED BY OWNER THROUGH THE CONSTRUCTION MANAGER

Section	01 32 00	Schedules and Reports
Section	01 45 10	Testing Laboratory Services
Section	01 71 50	Final Cleaning
Section	23 05 93	Testing, Adjusting, and Balancing

B. PROVIDED BY ALL CONTRACTORS AS APPLICABLE

Section	01 12 00	Multiple Contract Summary
Section	01 2 300	Alternates
Section	01 25 00	Contract Modification Procedures
Section	01 28 00	Schedule of Values
Section	01 29 00	Applications for Payment
Section	01 31 00	Project Meetings
Section	01 32 00	Schedules and Reports
Section	01 33 00	Submittal Procedures
Section	01 40 00	Quality Requirements
Section	01 45 10	Testing Laboratory Services (Paragraph 1.05)
Section	01 50 50	Temporary Facilities and Controls
Section	01 54 60	Environment Protection
Section	01 54 80	Utility Protection
Section	01 56 30	Water Control
Section	01 56 90	Housekeeping & Safety
Section	01 59 20	Offices and Sheds
Section	01 60 00	Product Requirements
Section	01 72 50	Work Layout
Section	01 73 10	Cutting and Patching
Section	01 77 00	Contract Closeout

All Contractors shall provide their Superintendents with radios capable of handling multiple channels and compatible with radios used by the Construction Manager.

All contractors shall subscribe to PlanGrid for use on this project. Number of users is up to the contractor, however, at a minimum your site personnel will be required to use this product to facilitate communication. PlanGrid will be used for the current construction documentation to include, current set, addenda, ASI, As Built Conditions, QA/QC, and Punch List. Visit the <u>www.PlanGrid.com</u> to determine subscription pricing. It is recommended that you have an office administrator to

assist your field personnel. PlanGrid is a tool for the construction phase and will not be used for bidding. Visit <u>www.skillmanplanroom.com</u> for bid documents

C. PROVIDED BY DESIGNATED CONTRACTORS

Section	01 21 00	Allowances
Section	01 51 50	Temporary Water
Section	01 51 60	Temporary Sanitary Facilities
Section	01 52 10	Construction Aids and Temporary Enclosures
Section	01 52 60	Rubbish Container
Section	01 53 10	Fences (Temporary Security)
Section	01 53 20	Tree and Plant Protection
Section	01 55 00	Access Roads and Parking Areas
Section	01 56 20	Dust Control
Section	01 56 80	Erosion Control
Section	01 57 60	Project Signs
Section	01 72 00	Field Engineering

3.03 **BID CATEGORIES**

A. <u>BID CATEGORY NO. 1 - WESTCHESTER INTERMEDIATE SITE -</u> <u>GENERAL TRADES</u>

General Requirements in Paragraph 3.02.B above.

	1	
Section	01 21 00	Allowances
Section	01 51 50	Temporary Water
Section	01 51 60	Temporary Sanitary Facilities
Section	01 52 10	Construction Aids and Temporary Enclosures
Section	01 52 60	Rubbish Container
Section	01 53 10	Fences (Temporary Security)
Section	01 53 20	Tree and Plant Protection
Section	01 55 00	Access Roads and Parking Areas
Section	01 56 20	Dust Control
Section	01 56 80	Erosion Control
Section	01 57 60	Project Signs
Section	01 72 00	Field Engineering
Section	02 41 20	Removals
Section	03 30 00	Concrete
Section	04 20 00	Unit Masonry
Section	05 50 00	Miscellaneous Metals
Section	06 10 00	Rough Carpentry
Section	06 16 00	Sheathing
Section	06 17 53	Shop-Fabricated Wood Trusses
Section	06 20 00	Finish Carpentry
Section	07 21 16	Batt and Blanket Insulation
Section	07 31 00	Shingle Roofing
Section	07 42 64	Metal Panel Soffit
Section	07 62 00	Sheet Metal Flashing
		-

SectionDownspoutsSection08 31 13Access DoorsSection08 33 00Rolling Doors and GrillesSection08 41 00Aluminum Entrances and StorefrontsSection08 71 00Door HardwareSection09 29 00Gypsum BoardSection09 91 00PaintingSection10 21 14Solid Plastic Toilet PartitionsSection10 28 13Toilet AccessoriesSection10 44 00Fire ExtinguishersSection10 75 00FlagpolesSection11 66 43ScoreboardsSection11 68 33Athletic Field EquipmentSection20 5 00Plumbing General ConditionsSection22 07 00Plumbing InsulationSection22 11 00Domestic Water DistributionSection22 31 00Sanitary Distribution SystemSection22 35 00Mechanical Materials and MethodsSection22 30 00Sanitary Distribution SystemSection23 05 00Mechanical Materials and MethodsSection23 400Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 05 26Secondary GroundingSection26 05 27Supporting DevicesSection26 05 28Supporting DevicesSection26 05 29Supporting DevicesSection26 05 21 00Wires and CablesSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection <td< th=""></td<>
Section08 31 13Access DoorsSection08 33 00Rolling Doors and GrillesSection08 41 00Aluminum Entrances and StorefrontsSection08 71 00Door HardwareSection09 29 00Gypsum BoardSection09 91 00PaintingSection10 21 14Solid Plastic Toilet PartitionsSection10 28 13Toilet AccessoriesSection10 28 13Toilet AccessoriesSection10 75 00FlagpolesSection11 66 43ScoreboardsSection11 66 43ScoreboardsSection11 68 33Athletic Field EquipmentSection20 5 00Plumbing General ConditionsSection22 07 00Plumbing InsulationSection22 11 00Domestic Water DistributionSection22 31 00Domestic Water SoftenersSection23 05 00Mechanical Materials and MethodsSection23 09 23Temperature ControlsSection23 400Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 05 26Secondary GroundingSection26 05 27Supporting DevicesSection26 05 73RacewaysSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 30Wires and Cables
Section08 33 00Rolling Doors and GrillesSection08 41 00Aluminum Entrances and StorefrontsSection08 71 00Door HardwareSection09 29 00Gypsum BoardSection09 91 00PaintingSection10 21 14Solid Plastic Toilet PartitionsSection10 21 14Solid Plastic Toilet PartitionsSection10 28 13Toilet AccessoriesSection10 44 00Fire ExtinguishersSection10 75 00FlagpolesSection11 66 43ScoreboardsSection11 66 43ScoreboardsSection13 34 16Grandstands and Press BoxSection22 05 00Plumbing General ConditionsSection22 07 00Plumbing InsulationSection22 11 00Domestic Water DistributionSection22 31 00Domestic Water SoftenersSection23 09 23Temperature ControlsSection23 400Exhaust Fans and AccessoriesSection23 400Electrical Work General ConditionsSection23 88 00Ductwork and AccessoriesSection26 05 29Supporting DevicesSection26 05 29Supporting DevicesSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 100Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section08 41 00Aluminum Entrances and StorefrontsSection08 71 00Door HardwareSection09 29 00Gypsum BoardSection09 91 00PaintingSection10 21 14Solid Plastic Toilet PartitionsSection10 28 13Toilet AccessoriesSection10 44 00Fire ExtinguishersSection10 75 00FlagpolesSection11 66 43ScoreboardsSection11 68 33Athletic Field EquipmentSection13 34 16Grandstands and Press BoxSection22 05 00Plumbing General ConditionsSection22 07 00Plumbing InsulationSection22 11 00Domestic Water DistributionSection22 31 00Sanitary Distribution SystemSection23 09 23Temperature ControlsSection23 400Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 05 26Secondary GroundingSection26 05 29Supporting DevicesSection26 05 29Supporting DevicesSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 100Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section08 71 00Door HardwareSection09 29 00Gypsum BoardSection09 91 00PaintingSection10 21 14Solid Plastic Toilet PartitionsSection10 28 13Toilet AccessoriesSection10 44 00Fire ExtinguishersSection10 75 00FlagpolesSection11 66 43ScoreboardsSection11 68 33Athletic Field EquipmentSection13 34 16Grandstands and Press BoxSection22 05 00Plumbing General ConditionsSection22 07 00Plumbing InsulationSection22 11 00Domestic Water DistributionSection22 31 00Sanitary Distribution SystemSection23 09 03Temperature ControlsSection23 400Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 05 29Supporting DevicesSection26 05 29Supporting DevicesSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 02 13Transformers - General Purpose Dry Type
Section09 29 00Gypsum BoardSection09 91 00PaintingSection10 21 14Solid Plastic Toilet PartitionsSection10 28 13Toilet AccessoriesSection10 44 00Fire ExtinguishersSection10 75 00FlagpolesSection11 66 43ScoreboardsSection11 68 33Athletic Field EquipmentSection13 34 16Grandstands and Press BoxSection22 05 00Plumbing General ConditionsSection22 07 00Plumbing InsulationSection22 11 00Domestic Water DistributionSection22 31 00Sanitary Distribution SystemSection23 05 00Mechanical Materials and MethodsSection23 05 00Mechanical Materials and MethodsSection23 34 00Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 05 26Secondary GroundingSection26 05 29Supporting DevicesSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 02 13Transformers - General Purpose Dry Type
Section09 91 00PaintingSection10 21 14Solid Plastic Toilet PartitionsSection10 28 13Toilet AccessoriesSection10 44 00Fire ExtinguishersSection10 75 00FlagpolesSection11 66 43ScoreboardsSection11 66 43ScoreboardsSection13 34 16Grandstands and Press BoxSection22 05 00Plumbing General ConditionsSection22 07 00Plumbing InsulationSection22 11 00Domestic Water DistributionSection22 31 00Sanitary Distribution SystemSection22 31 00Domestic Water SoftenersSection23 05 00Mechanical Materials and MethodsSection23 05 00Exhaust Fans and AccessoriesSection23 34 00Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 05 26Secondary GroundingSection26 05 29Supporting DevicesSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 22 13Transformers - General Purpose Dry Type
Section10 21 14Solid Plastic Toilet PartitionsSection10 28 13Toilet AccessoriesSection10 44 00Fire ExtinguishersSection10 75 00FlagpolesSection11 66 43ScoreboardsSection11 68 33Athletic Field EquipmentSection13 34 16Grandstands and Press BoxSection22 05 00Plumbing General ConditionsSection22 07 00Plumbing InsulationSection22 11 00Domestic Water DistributionSection22 31 00Sanitary Distribution SystemSection22 31 00Domestic Water SoftenersSection23 05 00Mechanical Materials and MethodsSection23 05 00Exhaust Fans and AccessoriesSection23 34 00Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 05 26Secondary GroundingSection26 05 273RacewaysSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 10Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section10 28 13Toilet AccessoriesSection10 44 00Fire ExtinguishersSection10 75 00FlagpolesSection11 66 43ScoreboardsSection11 68 33Athletic Field EquipmentSection13 34 16Grandstands and Press BoxSection22 05 00Plumbing General ConditionsSection22 07 00Plumbing InsulationSection22 11 00Domestic Water DistributionSection22 31 00Sanitary Distribution SystemSection22 42 00Plumbing FixturesSection23 05 00Mechanical Materials and MethodsSection23 05 00Mechanical Materials and MethodsSection23 34 00Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 05 26Secondary GroundingSection26 05 29Supporting DevicesSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 100Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section10 44 00Fire ExtinguishersSection10 75 00FlagpolesSection11 66 43ScoreboardsSection11 68 33Athletic Field EquipmentSection13 34 16Grandstands and Press BoxSection22 05 00Plumbing General ConditionsSection22 07 00Plumbing InsulationSection22 11 00Domestic Water DistributionSection22 31 00Sanitary Distribution SystemSection22 31 00Domestic Water SoftenersSection23 05 00Mechanical Materials and MethodsSection23 09 23Temperature ControlsSection23 34 00Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 05 26Secondary GroundingSection26 05 27Supporting DevicesSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 100Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section10 75 00FlagpolesSection11 66 43ScoreboardsSection11 68 33Athletic Field EquipmentSection13 34 16Grandstands and Press BoxSection22 05 00Plumbing General ConditionsSection22 07 00Plumbing InsulationSection22 11 00Domestic Water DistributionSection22 13 00Sanitary Distribution SystemSection22 31 00Domestic Water SoftenersSection22 30 00Plumbing FixturesSection23 05 00Mechanical Materials and MethodsSection23 09 23Temperature ControlsSection23 88 00Ductwork and AccessoriesSection26 05 26Secondary GroundingSection26 05 29Supporting DevicesSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 02 100Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section11 66 43ScoreboardsSection11 68 33Athletic Field EquipmentSection13 34 16Grandstands and Press BoxSection22 05 00Plumbing General ConditionsSection22 07 00Plumbing InsulationSection22 11 00Domestic Water DistributionSection22 11 00Domestic Water DistributionSection22 31 00Sanitary Distribution SystemSection22 42 00Plumbing FixturesSection23 05 00Mechanical Materials and MethodsSection23 09 23Temperature ControlsSection23 34 00Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 05 26Secondary GroundingSection26 05 29Supporting DevicesSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 100Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section11 68 33Athletic Field EquipmentSection13 34 16Grandstands and Press BoxSection22 05 00Plumbing General ConditionsSection22 07 00Plumbing InsulationSection22 11 00Domestic Water DistributionSection22 13 00Sanitary Distribution SystemSection22 31 00Domestic Water SoftenersSection22 42 00Plumbing FixturesSection23 05 00Mechanical Materials and MethodsSection23 09 23Temperature ControlsSection23 34 00Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 05 26Secondary GroundingSection26 05 73RacewaysSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 10Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section13 34 16Grandstands and Press BoxSection22 05 00Plumbing General ConditionsSection22 07 00Plumbing InsulationSection22 11 00Domestic Water DistributionSection22 13 00Sanitary Distribution SystemSection22 31 00Domestic Water SoftenersSection22 42 00Plumbing FixturesSection23 05 00Mechanical Materials and MethodsSection23 09 23Temperature ControlsSection23 88 00Ductwork and AccessoriesSection26 00 00Electrical Work General ConditionsSection26 05 26Secondary GroundingSection26 05 73RacewaysSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 100Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section22 05 00Plumbing General ConditionsSection22 07 00Plumbing InsulationSection22 11 00Domestic Water DistributionSection22 13 00Sanitary Distribution SystemSection22 31 00Domestic Water SoftenersSection22 42 00Plumbing FixturesSection23 05 00Mechanical Materials and MethodsSection23 09 23Temperature ControlsSection23 34 00Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 05 26Secondary GroundingSection26 05 73RacewaysSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 100Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section22 07 00Plumbing InsulationSection22 11 00Domestic Water DistributionSection22 13 00Sanitary Distribution SystemSection22 31 00Domestic Water SoftenersSection22 42 00Plumbing FixturesSection23 05 00Mechanical Materials and MethodsSection23 09 23Temperature ControlsSection23 34 00Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 05 26Secondary GroundingSection26 05 33RacewaysSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 10Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section22 11 00Domestic Water DistributionSection22 13 00Sanitary Distribution SystemSection22 31 00Domestic Water SoftenersSection22 42 00Plumbing FixturesSection23 05 00Mechanical Materials and MethodsSection23 09 23Temperature ControlsSection23 34 00Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 00 00Electrical Work General ConditionsSection26 05 26Secondary GroundingSection26 05 33RacewaysSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 00Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section22 13 00Sanitary Distribution SystemSection22 31 00Domestic Water SoftenersSection22 42 00Plumbing FixturesSection23 05 00Mechanical Materials and MethodsSection23 09 23Temperature ControlsSection23 34 00Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 00 00Electrical Work General ConditionsSection26 05 26Secondary GroundingSection26 05 33RacewaysSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 00Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section22 31 00Domestic Water SoftenersSection22 42 00Plumbing FixturesSection23 05 00Mechanical Materials and MethodsSection23 09 23Temperature ControlsSection23 34 00Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 00 00Electrical Work General ConditionsSection26 05 26Secondary GroundingSection26 05 29Supporting DevicesSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 00Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section22 42 00Plumbing FixturesSection23 05 00Mechanical Materials and MethodsSection23 09 23Temperature ControlsSection23 34 00Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 00 00Electrical Work General ConditionsSection26 05 26Secondary GroundingSection26 05 29Supporting DevicesSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 00Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section23 05 00Mechanical Materials and MethodsSection23 09 23Temperature ControlsSection23 34 00Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 00 00Electrical Work General ConditionsSection26 05 26Secondary GroundingSection26 05 29Supporting DevicesSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 00Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section23 09 23Temperature ControlsSection23 34 00Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 00 00Electrical Work General ConditionsSection26 05 26Secondary GroundingSection26 05 29Supporting DevicesSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 00Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section23 34 00Exhaust Fans and AccessoriesSection23 88 00Ductwork and AccessoriesSection26 00 00Electrical Work General ConditionsSection26 05 26Secondary GroundingSection26 05 29Supporting DevicesSection26 05 73RacewaysSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 00Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section23 88 00Ductwork and AccessoriesSection26 00 00Electrical Work General ConditionsSection26 05 26Secondary GroundingSection26 05 29Supporting DevicesSection26 05 33RacewaysSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 00Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section26 00 00Electrical Work General ConditionsSection26 05 26Secondary GroundingSection26 05 29Supporting DevicesSection26 05 33RacewaysSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 00Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section26 05 26Secondary GroundingSection26 05 29Supporting DevicesSection26 05 33RacewaysSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 00Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section26 05 29Supporting DevicesSection26 05 33RacewaysSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 00Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section26 05 33RacewaysSection26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 00Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section26 05 73Arc Flash Hazard Analysis/Short-Circuit StudySection26 21 00Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section26 21 00Wires and CablesSection26 22 13Transformers - General Purpose Dry Type
Section 26 22 13 Transformers - General Purpose Dry Type
1 5 5 1
Section 26 24 16 Panelboards
Section 26 24 19 Motor Starters
Section 26 27 25 Boxes
Section 26 27 26 Wiring Devices
Section 26 28 16 Disconnect Switches
Section 26 29 00 Circuits and Motor Disconnects
Section 26 43 00 Surge Protection Devices
Section 26 51 13 Lighting Fixtures
Section 26 56 68 Outdoor Sports Lighting for Football Field
Section 27 00 01 General Requirements for Communications
Section 27 00 02 Quality Assurance for Communications
Section 27 05 01 Operations and Maintenance of Communications
Systems
Section 27 05 02 Basic Materials and Methods for Communications

Section	27 05 26	Grounding and Bonding for Communication
Section	27 05 43	System Underground Ducts and Raceways for Communication Systems
Section	27 05 53	Identification for Communication Systems
Section	27 08 10	Verification Testing of Structured Cabling
Section	27 11 16	Communication Cabinets, Racks, Frames, and Enclosures
Section	27 11 26	Communications Rack Mounted Power Protection and Power Strips
Section	27 14 00	Communications Inter-Building Cabling
Section	27 15 13	Communications Copper Horizontal Cabling
Section	28 31 63	Fire Alarm and Detection System
Section	31 10 00	Site Clearing
Section	31 20 00	Earthwork
Section	31 25 13	Soil Erosion Control
Section	32 11 16	Granular Base Course
Section	32 12 16	Asphaltic Concrete Paving
Section	32 13 13	Portland Cement Concrete Paving
Section	32 13 80	Exterior Concrete and Site Equipment
Section	32 17 23	Roadway and Paving Marking
Section	32 17 25	Track Striping
Section	32 18 25	All Weather Latex Track Surface
Section	32 31 13	Chain Link Fences and Gates
Section	32 91 13	Soil Preparation
Section	32 92 19	Seeding
Section	32 92 23	Sodding
Section	33 11 00	Water Distribution Systems
Section	33 11 50	Exterior Water Lines, Fire Lines, and Facilities
Section	33 13 00	Disinfection of Water Distribution Systems
Section	33 30 00	Sanitary Sewage Systems
Section	33 40 00	Storm Sewage Systems

Clarification No. 1:

All contractors shall subscribe to PlanGrid for use on this project. The number of users is up to The contractor. PlanGrid will be used for the current construction documentation to include, current set, addenda, SI's, As-Built Conditions, QA/QC, and Punch Lists. Visit <u>www.PlanGrid.com</u> to determine subscription pricing. At a minimum, onsite personnel will be required to use this product to facilitate communication. It is recommended that an office administrator assist field personnel. PlanGrid is a tool for the construction phase and will not be used for bidding.

Clarification No. 2:

Private utilities locate will be required. The **Bid Category No. 1 Contractor is** to include in their bid, any costs associated to have a private utility locate company identify all utilities on the site outside the public utility boundaries.

Clarification No. 3:

The **Bid Category No. 1 Contractor** that have tracked mud or dirt on public roadways are responsible to remove it on a daily basis.

Clarification No. 4:

The **Bid Category No. 1 Contractor** is responsible to provide any special requirements and grading to provide equipment access for lifts, and lulls. All disturbed areas shall be restored to their original state.

Clarification No. 5:

The **Bid Category No. 1 Contractor** is to include in his bid, small tools, and a total of 100 manhours at a union laborer's pay rate (including all fringe benefits and payroll expenses) for work to be performed at the direction of the Construction Manager. At the end of the project, unused hours will be converted into a dollar amount per Wage Scale (including fringe benefits) and included as a deduct Change Order.

Clarification No. 6:

The **Bid Category No. 1 Contractor** is to include \$16,000 in their bid for costs associated with the submittal website and document management subscription. Any unused amount will be credited back to the Owner as a deductive Change Order.

Clarification No. 7:

Regarding Specification Section 01 56 80 - Erosion Control; The **Bid Category No. 1 Contractor** is responsible to prepare and submit a complete Notice of Intent Letter (and pay NOI letter fees) to IDEM. The **Bid Category No. 1 Contractor** is also responsible for the SWPPP as indicated on the Contract Documents including site inspection and the maintenance log.

B. <u>BID CATEGORY NO. 2 - LIBERTY INTERMEDIATE SITE - GENERAL</u> <u>TRADES</u>

General Re	quirements in P	aragraph 3.02.B above.
Section	01 21 00	Allowances
Section	01 51 50	Temporary Water
Section	01 51 60	Temporary Sanitary Facilities
Section	01 52 10	Construction Aids and Temporary Enclosures
Section	01 52 60	Rubbish Container
Section	01 53 10	Fences (Temporary Security)
Section	01 53 20	Tree and Plant Protection
Section	01 55 00	Access Roads and Parking Areas
Section	01 56 20	Dust Control
Section	01 56 80	Erosion Control
Section	01 57 60	Project Signs
Section	01 72 00	Field Engineering
Section	02 41 20	Removals
Section	03 30 00	Concrete
Section	04 20 00	Unit Masonry
Section	05 50 00	Miscellaneous Metals
Section	06 10 00	Rough Carpentry
Section	06 16 00	Sheathing
Section	06 17 53	Shop-Fabricated Wood Trusses
Section	06 20 00	Finish Carpentry
Section	07 21 16	Batt and Blanket Insulation
Section	07 31 00	Shingle Roofing
Section	07 42 64	Metal Panel Soffit
Section	07 62 00	Sheet Metal Flashing
Section	07 71 19	Aluminum Fascias, Copings, Gutters, and
		Downspouts
Section	07 90 00	Joint Sealants
Section	08 31 13	Access Doors
Section	08 33 00	Rolling Doors and Grilles
Section	08 41 00	Aluminum Entrances and Storefronts
Section	08 71 00	Door Hardware
Section	09 29 00	Gypsum Board
Section	09 91 00	Painting
Section	10 21 14	Solid Plastic Toilet Partitions
Section	10 28 13	Toilet Accessories
Section	10 44 00	Fire Extinguishers
Section	10 75 00	Flagpoles
Section	11 66 43	Scoreboards
Section Section	11 68 33	Athletic Field Equipment Grandstands and Press Box
Section	13 34 16	
Section	22 05 00 22 07 00	Plumbing General Conditions
Section	22 07 00	Plumbing Insulation Domestic Water Distribution
Section	22 11 00 22 13 00	Sanitary Distribution System
Section	22 13 00	Samary Distribution System

Section22 31 00Domestic Water SoftenersSection22 42 00Plumbing FixturesSection23 05 00Mechanical Materials and MethodsSection23 09 23Temperature ControlsSection23 34 00Exhaust Fans and AccessoriesSection23 88 00Ductwork and Accessories	
Section23 05 00Mechanical Materials and MethodsSection23 09 23Temperature ControlsSection23 34 00Exhaust Fans and Accessories	
Section23 09 23Temperature ControlsSection23 34 00Exhaust Fans and Accessories	
Section 23 34 00 Exhaust Fans and Accessories	
Section 22.88.00 Ductiver's and Accessories	
Ductwork and Accessories	
Section 26 00 00 Electrical Work General Conditions	
Section 26 05 26 Secondary Grounding	
Section 26 05 29 Supporting Devices	
Section 26 05 33 Raceways	
Section 26 05 73 Arc Flash Hazard Analysis/Short-Circuit Study	
Section 26 21 00 Wires and Cables	
Section 26 22 13 Transformers - General Purpose Dry Type	
Section 26 24 16 Panelboards	
Section 26 24 19 Motor Starters	
Section 26 27 25 Boxes	
Section 26 27 26 Wiring Devices	
Section 26 28 16 Disconnect Switches	
8	
Section 26 51 13 Lighting Fixtures	
Section 26 56 68 Outdoor Sports Lighting for Football Field	
Section 27 00 01 General Requirements for Communications	
Section 27 00 02 Quality Assurance for Communications	
Section 27 05 01 Operations and Maintenance of Communication	S
Systems	
Section 27 05 02 Basic Materials and Methods for Communication	ns
Section 27 05 26 Grounding and Bonding for Communication	
System	
Section 27 05 43 Underground Ducts and Raceways for	
Communication Systems	
Section 27 05 53 Identification for Communication Systems	
Section 27 08 10 Verification Testing of Structured Cabling	
Section 27 11 16 Communication Cabinets, Racks, Frames, and	
Enclosures	
Section 27 11 26 Communications Rack Mounted Power Protecti	on
and Power Strips	
Section 27 14 00 Communications Inter-Building Cabling	
Section 27 15 13 Communications Copper Horizontal Cabling	
Section 28 31 63 Fire Alarm and Detection System	
Section 31 10 00 Site Clearing	
Section 31 20 00 Earthwork	
Section 31 25 13 Soil Erosion Control	
Section 32 11 16 Granular Base Course	
Section 32 12 16 Asphaltic Concrete Paving	
Section 32 13 13 Portland Cement Concrete Paving	

Section	32 13 80	Exterior Concrete and Site Equipment
Section	32 17 23	Roadway and Paving Marking
Section	32 17 25	Track Striping
Section	32 18 25	All Weather Latex Track Surface
Section	32 31 13	Chain Link Fences and Gates
Section	32 91 13	Soil Preparation
Section	32 92 19	Seeding
Section	32 92 23	Sodding
Section	33 11 00	Water Distribution Systems
Section	33 11 50	Exterior Water Lines, Fire Lines, and Facilities
Section	33 13 00	Disinfection of Water Distribution Systems
Section	33 30 00	Sanitary Sewage Systems
Section	33 40 00	Storm Sewage Systems

Clarification No. 1:

All contractors shall subscribe to PlanGrid for use on this project. The number of users is up to The contractor. PlanGrid will be used for the current construction documentation to include, current set, addenda, SI's, As-Built Conditions, QA/QC, and Punch Lists. Visit <u>www.PlanGrid.com</u> to determine subscription pricing. At a minimum, onsite personnel will be required to use this product to facilitate communication. It is recommended that an office administrator assist field personnel. PlanGrid is a tool for the construction phase and will not be used for bidding.

Clarification No. 2:

Private utilities locate will be required. The **Bid Category No. 2 Contractor is** to include in their bid, any costs associated to have a private utility locate company identify all utilities on the site outside the public utility boundaries.

Clarification No. 3:

The **Bid Category No. 2 Contractor** that have tracked mud or dirt on public roadways are responsible to remove it on a daily basis.

Clarification No. 4:

The **Bid Category No. 2 Contractor** is responsible to provide any special requirements and grading to provide equipment access for lifts, and lulls. All disturbed areas shall be restored to their original state.

Clarification No. 5:

The **Bid Category No. 2 Contractor** is to include in his bid, small tools, and a total of 100 manhours at a union laborer's pay rate (including all fringe benefits and payroll expenses) for work to be performed at the direction of the Construction Manager. At the end of the project, unused hours will be converted into a dollar amount per Wage Scale (including fringe benefits) and included as a deduct Change Order.

Clarification No. 6:

The **Bid Category No. 2 Contractor** is to include \$16,000 in their bid for costs associated with the submittal website and document management subscription. Any unused amount will be credited back to the Owner as a deductive Change Order.

Clarification No. 7:

Regarding Specification Section 01 56 80 - Erosion Control; The **Bid Category No. 2 Contractor** is responsible to prepare and submit a complete Notice of Intent Letter (and pay NOI letter fees) to IDEM. The **Bid Category No. 2 Contractor** is also responsible for the SWPPP as indicated on the Contract Documents including site inspection and the maintenance log.

END OF SECTION 01 12 00