

ADDENDUM NO. 2

December 2, 2022

VALPARAISO HIGH SCHOOL KITCHEN SERVERY RENOVATION AND RELATED WORK

Valparaiso, IN 46385

TO: ALL BIDDERS OF RECORD

This Addendum forms a part of and modifies the Bidding Requirements, Contract Forms, Contract Conditions, the Specifications, and the Drawings dated October 4, 2022, by Gibraltar Design. Acknowledge receipt of the Addendum in the space provided on the Proposal Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of Pages ADD 2-1 and attached Addendum No. 2 from Gibraltar Design dated December 1, 2022 consisting of 1 page.

ADDENDUM ONE

Addendum One (AD.02) to the drawings and specifications prepared by Gibraltar Design and The Skillman Corporation for **Valparaiso HS Kitchen Servery Renovation and Related Work** for Valparaiso School Corporation, Valparaiso, Indiana.

All Contractors bidding on this project shall read all of the items covered below and shall comply with all of the requirements as set forth, including any necessary refinements or additions generated by this Addendum, Addendum One, and required by the intent of the original BID CATEGORY NO. Documents. All Contractors shall acknowledge on their bid form that they have received this Addendum and Addendum One and include the appropriate content of same within their bid proposal.

DRAWINGS

1. Sheet A-101

- A. Concerning the floor finish in Servery E-205 Contractor is to do the following.
 - 1. Remove Tile floor including mud set bed.
 - 2. Prepare existing slab as required to receive Ardex K15 Self-Leveling Underlayment.
 - 3. Utilize Ardex K15 Self-Leveling Underlayment so that when resinous flooring is applied the finish floor is level with surrounding Corridor and Kitchen.
 - 4. Confirm with resinous flooring manufacturer that Ardex K15 Self-Leveling Underlayment is an acceptable product to use under resinous flooring system.

Page 1 constitutes the total makeup of **Addendum Two**.