

April 24, 2023

COLUMBIA ELEMENTARY SCHOOL & LANDIS ELEMENTARY SCHOOL - SITE IMPROVEMENTS - BID PACKAGE #2 Logansport, IN 46947

TO: ALL BIDDERS OF RECORD

This Addendum forms a part of and modifies the Bidding Requirements, Contract Forms, Contract Conditions, the Specifications, and the Drawings dated March 27, 2023 by Gibraltar Design. Acknowledge receipt of the Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of Pages ADD 3-1 and attached Addendum No. 3 from Gibraltar Design dated April 24, 2023, consisting of 1 page.



ADDENDUM THREE

Addendum Three (AD.03) to the drawings and specifications prepared by Gibraltar Design and The Skillman Corporation for Columbia Elementary School and Landis Elementary School Site Improvements for Logansport Community School Corporation, Logansport, Indiana.

All Contractors bidding on this project shall read all of the items covered below and shall comply with all of the requirements as set forth, including any necessary refinements or additions generated by this Addendum and required by the intent of the original contract documents. All Contractors shall acknowledge on their bid form that they have received this Addendum and Addendum One, Addendum Two and include the appropriate content of same within their bid proposal.

DRAWINGS

- 1. Sheets C-103, C-106
 - A. Area designated as "soft surface" on the drawings to receive final elevation of 12" below the top of curb/perimeter final elevation to the top of the compacted subgrade, to allow 12" depth of soft surface material. Soft surface material to be provided by Owner.

2. Sheets C-202, C-203

A. Area designated as "soft surface" on the drawings to receive final elevation of 12" below the top of curb/perimeter final elevation to the top of the compacted subgrade, to allow 12" depth of soft surface material. Soft surface material to be provided by Owner.

Page 1, constitute the total makeup of Addendum Three.



Y:\23-123 Logansport CSC - Columbia and Landis ES Site Improvements\Specs\Addendum Three\AD03.doc