

ADDENDUM NO. 2

April 29, 2024

**DUNELAND BAILLY ELEMENTARY SCHOOL –
GYMNASIUM RENOVATION AND RELATED WORK
Chesterton, IN 46304**

TO: ALL BIDDERS OF RECORD

This Addendum forms a part of and modifies the Bidding Requirements, Contract Forms, Contract Conditions, the Specifications, and the Drawings dated March 29, 2024 by Gibraltar Design, Inc. Acknowledge receipt of the Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of Pages ADD 2-1 and attached Addendum No. 2 from Gibraltar Design, Inc. dated April 26, 2024 and consisting of 1 page.

ADDENDUM TWO

Addendum Two (AD.02) to the drawings and specifications prepared by Gibraltar Design for **Duneland Bailly ES – Gymnasium Renovation and Related Work**, for Duneland School Corporation, Chesterton, Indiana.

All Contractors bidding on this project shall read all of the items covered below and shall comply with all of the requirements as set forth, including any necessary refinements or additions generated by Addendum No. 1 and this Addendum and required by the intent of the original contract documents. All Contractors shall acknowledge on their bid form that they have received this Addendum and include the appropriate content of same within their bid proposal.

SPECIFICATIONS

1. Not Used

DRAWINGS

2. Sheets A-301 and A-501

A. Clarification:

1. No Reflected ceiling is provided since there metal building is exposed steel framing.
2. There is no steel in place at 20', that is the desired opening height for the divider curtain is at 20', the Divider Curtain supports are off of the center structural bent-beam with a structural support attached to that beam and cantilevered out to hang the cables supporting the Divider Curtain – see Detail on Sheet A-501. The curtain sits to the side of the new wall system centered on the structural columns.
3. Only the noted gymnasium equipment indicated for demolition and/or reinstallation are required to be performed by the Contractor, all other equipment is to be taken care of by the Owner.

Pages 1 through 1, inclusive, and No Full-Size Drawings, constitute the total makeup of **Addendum Two**.